

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 2520-2080:0101

Page 1 of 1

CATEGORY: 2520 -- TREATED LUMBER

LISTEE: Viance LLC 200 East Woodlawn Road, Suite 350, Charlotte, NC 28217
Contact: Kevin Archer (704) 522-0825 Fax (805) 937-4573
Email: karcher@viance.net

DESIGN: D-Blaze Fire Retardant Treated Lumber. Products are pressure impregnated treated lumber with "D-Blaze" fire retardant chemical. D-Blaze covers the following species of lumber: Alpine Fir, Basswood, Douglas Fir, Lodgepole Pine, Red Oak, Southern Yellow Pine, Western Hemlock, White Fir, and White Spruce.
Refer to listee's printed installation instructions for additional detailed product description and constructions.

RATING: Class A products in accordance with ASTM E-84.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product identification, classification, and UL label.

APPROVAL: Listed as fire retardant treated lumber for interior use only. Listed as Class A products in accordance with ASTM E-84. In test of 30 minute duration, flame spread did not progress more than 10.5 feet beyond the centerline of the burners and no significant progressive combustion was present. The lumber must be pressure treated at the factory under authorized service inspection.

02-21-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division